



Bathing establishment sheet

Name of bathing establishment	FLAVIO
Address	Via Arenale di Ponente 56
City	Forte dei Marmi (Lu)
Contacts	Tel. +39 0584 81209 – +393381576833 info@bagnoflavioversilia.it
Website	https://www.bagnoflavioversilia.com/

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each sheet. The Association is not responsible for any significant changes made to the property after the visit.

Summary

Bathing establishment sheet.....	1
Arrival at the facility	2
Private/public parking	2
Pathway from the parking lot to the main entrance.....	2
Reception welcome	3
Bar/restaurant	4
Internal pathways and common services	5
Internal pathways.....	5
Toilet and shower accessible to guests with reduced mobility	5
Changing room	7
Beach	8
Children's play area.....	9
Pool	9
Medical practices/health facilities	9

Project carried out with the contribution of





Arrival at the facility

Private/public parking

Presence of private parking	YES
Fund type of private parking	asphalt
Presence of parking space reserved for people with disabilities	NO
Public parking nearby	YES
Fund type of public car park	asphalt
	

Pathway from the parking lot to the main entrance

Pathway from the parking lot to the entrance	flat
There are indicators and tactile maps	NO
Useful width of door/entrance passage	greater than 90 cm







Reception welcome

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By telephone <input checked="" type="checkbox"/> On site
Presence of multilingual staff	not detected
Presence of plant map with legend of services present	NO
Presence of visuo-tactile map	NO
Noticeboard/information panels with an average height of 130 cm in a well-lit area and a character size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff has followed a training course on welcoming people with various disabilities	NO





Bar/restaurant

Type of venue	Bar/restaurant
Access to the venue	via 2 steps, one of 4 cm for access to the bar and level for the area with the tables
Useful width of door/entrance passage	greater than 90 cm
Bar counter	110cm
Type of tables	with 4 legged
Space under the floor tables	65cm
Multilingual menu	not detected
Menu with large print characters	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of food for celiacs	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input type="checkbox"/> ice cream <input type="checkbox"/> pre-packaged foods
	





Internal pathways and common services

Internal pathways

Indicate whether the entrance-beach connection routes are flat or with ramps in addition to those already described	obstacle-free routes
---	----------------------


Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the venue	via a 9 cm step that can be overcome via a removable ramp, length 70 cm, width 70 cm and 7% slope
Useful width of entrance door	86 cm
Toilet height	50cm
Toilet seat with open front tooth	YES
Support handles	on both sides

Project carried out with the contribution of






Flexible shower next to the toilet	YES
Free space on the sides of the toilet	to the leftChoose an item. To the rightChoose an item. frontChoose an item.
Electric bell/telephone	YES
Washbasin with space underneath for a wheelchair	71 cm
Height from the ground to the lower edge of the mirror	sufficient for use by a person in a wheelchair
Baby changing table	not detected
	
Shower accessible to guests with reduced mobility available	Yes, outdoors without a roof
Access to the shower room if separated from the toilet room	flat
Useful width of entrance door/gap if separated from the toilet room	greater than 90 cm
Shower type	open type
Floor-level shower	Yes
Shower chair	missing
Support handle	missing
Presence of shower head or latch	fixed shower head





Electric bell/telephone	NO
	Floor-level outdoor showers with hot water

Changing room

Changing room accessible to guests with reduced mobility available	YES
Access to the venue	via 1 step of 9 cm which can be overcome via a removable ramp length 70 cm, width 70 cm and slope 7%
Useful width of door/entrance passage	86 cm
Dimensions of the changing room	sufficient for guest maneuvering in a wheelchair
Presence of cot	NO
Coat stand height from the floor	less than 140 cm and accessible to people in wheelchairs





Project promoted by



Regione Toscana

Beach

Type of beach	sand
Access to the beach	flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100cm
	
Removable platform between walkway and umbrella station to facilitate passage and parking with the wheelchair	YES
Available amphibious bathing chair for people with reduced mobility owned or through a bathing association	YES

Project carried out with the contribution of



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



Children's play area

Children's play area	not detected
----------------------	--------------

Pool

The property has a swimming pool	NO
----------------------------------	----

Medical practices/health facilities

Hospitals near the facility	Versilia Hospital SS 1, +39 335 55049 Camaiole LU Telephone: +39 0584 6051
Other healthcare facilities	Health District ASL No. 12 Viareggio Via Sant 'Elme, 30 Tel. +39 0584 83873 Green Cross Viale Italice, corner. via Risorgimento Tel. +39 0584 84013 Free first aid for white codes Night medical guard Tel. 0584 83896 (8pm-8am) Misericordia Via PI da Carrara, 32 Tel. +39 0584 752133/ 752149

Project carried out with the contribution of



Project promoted by



Regione Toscana

	<p>Medical service "San Camillo" nursing home Via PI da Carrara, 37 Tel. +39 0584 7391</p> <p>Dialysis service c/o Croce Verde Viale Italice, ang. via Risorgimento Tel. +39 058484013 affiliated with AUSL</p>
--	---

TESTED BY: Handy Superabile Social Promotion Association. in summer 2023

Project carried out with the contribution of



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità

